Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 11:46 am

Gal/Min

PWS ID: UTAH05022 Name: LUCERNE VALLEY CAMPGROUND

Legal Contact USFS - ASHLEY NATIONAL FOREST SO Rating: Approved

LANCE VALENTINE Rating Date: 04/09/1996

Address: 355 N VERNAL AVE Activity Status: Active

VERNAL, UT 84078

Phone Number: 435-781-5142

City Served (Area):

County: DAGGETT COUNTY

Gal/Day

System Type: Non-community

Last Inv Update: 08/18/2010

Activity Status Cd: Active

Last Snty Srv Dt: 10/02/2008

Total Dsgn Cap:

Surveyor: DONALD K LORE

Total Emerg Cap:

Oper Period: 5/1 to 9/30

Contacts

| Contact | | Phone Numbers | | | | | | | |
|---------|------------------|---------------|--------------|-----------|----------------------|--|--|--|--|
| Type | Name Title | | Office | Emergency | Email Address | | | | |
| AC | VALENTINE, LANCE | FOREST ENGIN | 435-781-5113 | | lvalentine@fs.fed.us | | | | |

Service Connections

| Connection | | | Number | |
|------------|-----------------|------------|-------------|----------------------------|
| Туре | Meter Type Code | Meter Size | Connections | 5 |
| Combined | Metered | 0 | 30 | |
| | | | 30 | — Гotal Svc Connections |

Storage

Total Storage: 60,000 GAL Number of Units: 2 Adequate Capacity: NO

| | | | | Constr | Overflow | Activity | |
|-------|------------------------|--------|------------------|--------|----------|----------|---------|
| No. | Name | Type | Effective Volume | Matri | Elev | Status | Press'd |
| ST001 | STORAGE FACILITY ST001 | Ground | 10,000 GAL | Steel | | Α | |
| ST002 | STORAGE FACILITY ST002 | Ground | 50,000 GAL | Steel | | Α | |

Distribution System

| Pump Type | Total Dy | n Head | Pressure | Cross | Auhority |
|-----------|----------|--------|----------|------------|-----------|
| | ft H2O | P.S.I. | Adequate | Connection | Statement |
| | | | No | | _ |

Sources

| No. | Source Name | Activity Status | Source Type | Well Dia. | Safe Yield * | Pump Capacity | Location Data On File | Water Type | Availability | Period of Operation | Grnd Wtr Indicator |
|-------|-------------|--------------------|----------------|--------------|-----------------|------------------|-----------------------------|---------------|--------------|------------------------|-----------------------|
| WS001 | WELL #1 | Active | WL | 8 | 140 GPM | 130 GPM | Yes | GW | Seasonal | 5/1 to 9/30 | |
| WS002 | WELL #2 | Active | WL | 8 | 80 GPM | 80 GPM | Yes | GW | Seasonal | 5/1 to 9/30 | |

^{*}Reports measured flow for wells, approved design capacity for all other sources.